

2 of 2



Estb No 13-51-08394

STATE OF FLORIDA
DEPARTMENT OF HEALTH

ESTABLISHMENT NAME Winston Park K-8
13200 SW 79 ST, MIAMI, 33183

COMMENTS AND INSTRUCTION

15 - Repair or replace the hand dryers of bathrooms 1009, 1029 and 1049. Provide paper towels for the handwashing facilities of the above noted bathrooms until the hot-air hand drying devices are repaired or replaced.

5 - Remove 2 pieces of metal structures lying on the floor of the patio in front of the metallic cabinets.

Copy of Inspection Report Received by: [Signature]
Health Department Inspector Oswaldo Sampaio Date: 09/24/2009

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT



PURPOSE:

FOOD SERVICE
INSPECTION REPORT

RESULTS

NAME OF ESTABLISHMENT Winston Park K-8
ADDRESS 13200 SW 79 ST CITY MIAMI
OWNER MDCPS ZIP 33183
PERSON IN CHARGE Carlos Diaz PHONE (305) 386 76 22

BEGIN END DATE POSITION # CERTIFICATE NUMBER TYPE
100200 09 24 09 67699 13 - 48 - 14965

This report is a summary of the inspection and is not intended to be used as a legal document. The inspector is not responsible for the accuracy of the information provided. The establishment is responsible for the accuracy of the information provided.

FOOD SUPPLIES
FOOD PROTECTION
PERSONNEL
EQUIPMENT/UTENSILS
OTHER FACILITIES AND OPERATIONS
TEMPORARY FOOD SERVICE EVENTS
VENDING MACHINES
MANAGER CERTIFICATION
CERTIFICATES AND FEES
INSPECTION ENFORCEMENT

ITEM NUMBERS COMMENTS AND INSTRUCTIONS
(continue on attached sheets)

- 38 Repair or replace the air curtain (fly fan) of the kitchen's back door (work order # 745662 placed).
- 37-38 Replace the broken lids of one 8 yds garbage dumpster (outside area)
- 39 Repair or replace the handle (broken with sharp edges) of one drinking fountain in the dining area (cafeteria).

Osvaldo Saiz
[Signature] (305) 668 7243
09/24/2009

1 of 2

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC-PRIVATE SCHOOL
INSPECTION REPORT

TYPE:

PURPOSE:

NAME OF SCHOOL Winston Park K-8
ADDRESS 13200 SW 79 ST CITY MIAMI
OWNER MDCPS ZIP 33183
PERSON IN CHARGE Carlos Diaz PHONE (305) 386 7622

CENSUS
1384

RESULTS

BEGIN END
230 530

DATE

DATE POSITION # PERMIT NUMBER
092409 67699 13-51-08394

FEMALES
655

MALES
729

SCHOOL SANITATION

LIQUID SOLID WASTE

SAFETY

BUILDINGS

SANITARY FACILITIES

WATER SUPPLY

VECTOR VERMIN CONTROL


OTHER

Toxic substances

ITEM NUMBERS

COMMENTS AND INSTRUCTIONS

- 1-28 Remove or keep out of reach of children toxic substances (cleaners, disinfectants and air fresheners) found at the reach of the students in some school's classrooms (corrected during inspection)
- 11 Repair water leak (from the flush valve) in 2 toilets in bathroom 901-A
- 11 Repair 2 urinals. One in bathroom 901-A (no flushing) and one in bathroom #1010 (clogged).
- 11 Repair 2 out of 4 faucets (no water) of the handwash sink in bathroom #1029 and the faucet of the handicapped stall (same problem - same bathroom)
- 15 Provide paper towels for the handwashing sinks in bathrooms 1105 and 1106

Oswaldo Saizpe
X 

(305) 668 7243
09/24/2009